

## AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE

PAGE OF PAGES

1

4

2. AMENDMENT/MODIFICATION NO. 2	3. EFFECTIVE DATE See Block 16C	4. REQUISITION/PURCHASE REQ. NO. 4200541292	5. PROJECT NO. (If applicable) 99018
6. ISSUED BY CODE	OP-ES	7. ADMINISTERED BY (If other than Item 6) Same as block 6	CODE
John F. Kennedy Space Center, NASA Procurement Office, OP-ES Kennedy Space Center, FL 32899			

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and Zip Code)  Potential Contractors	<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION. NNK15541292R	<input type="checkbox"/> 10A. MODIFICATION OF CONTRACT/ORDER NO.
		<input type="checkbox"/> 10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

## 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[ X ] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended, [ x ] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

## 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [ ] [ ] is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of Amendment 2 is to:

- A. Provide Government answers submitted by potential bidders.
- B. All other terms and conditions remain unchanged.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		BY (Signature of Contracting Officer)	

**A.) ANSWERS TO BIDDERS QUESTIONS:**

1. **REFERENCE:** SF 1442 front sheet and Page 75 of Solicitation

**QUESTION:** Is a Bid Bond required? The SF 1442 form indicates "not required". Page 75, Section L.c.8 of the Solicitation indicates "SF 24 Bid Bond" is required.

**RESPONSE:** Yes

2. **REFERENCE:** Specification Section 013526 Governmental Safety Requirements, Page 32, Paragraph 1.6.1.1 Site Safety and Health Officer (SSHO); Which states the SSHO shall be onsite at all times work is being performed.

**QUESTION:** May the Superintendent be the SSHO if they meet the requirements?

**RESPONSE:** 1.6.1.1.5 The Contractor Quality Control (QC) Personnel. The Contractor Quality Control (QC) person cannot be the SSHO on this project, although the QC has safety inspection responsibilities as part of the QC duties. The Project Superintendent or other Contractor personnel may act on behalf of the SSHO for a period of no more than thirty (30) days annually, provided that the individual meets the same competency level of the SSHOs, demonstrates the proficiency required, and is approved by the Contracting Officer in consultation with the NAVFAC MARIANAS Site Safety and Health Manager.

3. **REFERENCE:** Fed Biz Ops Website and SF 1442 Block 18


**QUESTION:** How many Amendments have been issued to date? Plans and specifications are assigned "Amendment 1" on the FBO website and Amendmen 2 on FBO is actually Amendment 1 (the SF 30). Additionally, Amendment 1 does not have an issue date that I can determine, which is needed for the SF 1442. Is the issue date for Amendment 1 May 4, 2015?

**RESPONSE:** Two Amendments have been issued to date (Including this Amendment 2). Amendment 1 was issued May 4, 2015. Amendment 2 was issued May 22, 2015.

4. **REFERENCE:** Drawing 79K39914 Sheet M100

**QUESTION:** At the exterior of the building and on the exterior air conditioning duct is a note "DUCT SUPPORT WITH SADDLES". Please provide a sketch/detail and quantity of supports for the exterior duct.

**RESPONSE:** See Attached Sketch.



PLACE SUPPORT ON NEW 6" CONC. SLAB  
SUPPORT TO BE NOT DIPPED GALV. AFTER FABRICATION  
CRUST TO BE NON-STEEL & NON-METALIC

***B.) ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED***